



City of Blue Lake

Wastewater Treatment Plant-Solar Project

Addendum #1

Amendment Issuance Date: November 10, 2022
Bid Closing Date: November 18, 2022
Bid Contact Person: Mandy Mager, City Manager
Contact Number: 707-668-5655

A. This Addendum shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents, this Addendum shall govern and take precedence. BIDDERS MUST SIGN THE AMENDMENT AND SUBMIT IT WITH THEIR BIDS.

B. Bidders are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Addendum. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

Except as described below, the original bid document remains unchanged. The bid documents are modified and/or clarified, as follows:

1. *The City of Blue Lake requests that all bidders will incorporate a minimum mounting height of 8' into the design of the ground mounted solar array in order to minimize the chance of damage to the installed equipment. The minimum mounting height for the solar panels should be 8' and no balance of systems equipment shall be mounted at the array below 8'. All conductors below 8' shall be in conduit to protect from physical damage.*

BIDDER MUST ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND ATTACHING THE SIGNED ADDENDUM TO THE BID FORM:

Company Name: _____

Contact Person: _____

Signature: _____

Date: _____