

May 2, 2023

Fire Department Comments, for Blue Lake Fire District

Baduw”at Community-Powers Creek Business Park, Blue Lake

- Fire Hydrant required within 100’ of Fire Department Connection. Fire Hydrant to be installed on north side of Taylor Way IFO project.
- Fire Hydrant(s) shall be commercial spec- 1-4” and 2-2 ½” discharges.
- 2 Fire Hydrants located on north side of property adjacent to trail.
- Removable Bollards installed at NE corner, end of parking for Fire Department trail access.
- “Breezeway” between Commercial/Retail buildings shall accommodate Height and Width of Fire Apparatus.

Ed Laidlaw, Fire Marshal
Arcata Fire District
Office | (707) 825-2000
prevention@arcatafire.org
www.arcatafire.org

